READ ALL CAUTIONS CAREFULLY BEFORE INSTALLING PUMP



SERIES 100/150 INSTRUCTION MANUAL

TABLE OF CONTENTS

	<u>i aye</u>
SAFETY INSTRUCTIONS	2
INTRODUCTION	2
PRECAUTIONS FOR OPERATION	
INSTALLATION, PIPING AND WIRING	
BLEED VALVE INSTALLATION (Optional)	6
CURRENT INTERRUPTOR (Optional)	
MAINTENANCE	8
SERVICE AND REPAIRS	9
TROUBLESHOOTING	
PARTS LIST (EXPLODED PUMP ASSEMBLY).	
REPLACEMENT KITS (EXPLODED WET END ASSEMBLY)	

SAFETY INSTRUCTIONS READ ALL INSTRUCTIONS PRIOR TO USE

DANGER Secure chemicals & metering pumps, making them inaccessible to children & pets.

*** DO NOT PUMP FLAMMABLE LIQUIDŠ.

- *** Do not cut the plug or ground lug off the electrical cord. Consult a licensed electrician for proper installation or replacement.
- WARNING To reduce the risk of electrical shock-before maintenance, repair, or moving, always disconnect the power to the pump by unplugging from wall outlet.
- WARNING Always wear protective clothing, including gloves and safety glasses, when working on or near chemical metering pumps.
- ** Inspect tubing regularly for cracking or deterioration and replace as necessary. (Always wear protective clothing and safety glasses when inspecting tubing.)
- ** Use **CAUTION** to keep fingers away from rotating parts.
- ** If pump is exposed to direct sunlight, use a UV resistant tubing.
- ** Follow directions and warnings provided from the chemical manufacturer. The user is responsible for determining the chemical compatibility with the chemical feed pump.
- ** Make sure the voltage on the pump name tag matches the installation voltage. If pump fails to start, check line voltage.
- ** Consult with local health officials and/or qualified water conditioning specialists when treating potable water.
- ** Always depressurize system prior to installation or disconnecting the metering pump tubing.
- ** If injection point is lower than the chemical tank and pump, install an anti-siphon valve.
- ** **DO NOT MODIFY PUMP.** This poses a potentially dangerous situation and will void the warranty. Hand tighten plastic <u>connections</u> (**Do not use wrench**).
- **CAUTION** All pumps are factory tested with water. Remove tubing and thoroughly dry if the chemical being pumped will react with water (for example sulfuric acid).
- * Hand tighten plastic connections (Do not use wrench).
- * Consult licensed plumber and electrician before installation to conform to local codes.
- * NOTE: For accurate volume output, pump must be calibrated under all operating conditions.

INTRODUCTION

Series 100/150 are diaphragm-type metering pumps. A fluid is pumped from a chemical storage tank to the point of injection by the pulsing action of the diaphragm. The four check valves (top and bottom of pump head, strainer assembly, and injection assembly) keep the fluid flowing toward the point of discharge. To insure the solution being pumped can only go forward, it is important that all check valves provide positive, non-leaking backflow prevention. The wetted end (those parts that contact the solution being pumped) is constructed of SAN, PVC, TFE, Hypalon®, and polyethylene. These materials are very resistant to most chemicals. However, there are



Dago

some chemicals, such as strong acids or organic solvents, which cause deterioration of some elastomer and plastic parts, such as diaphragm, valve seat, or head. Alternate materials such as Viton®, polypropylene is available on request. Contact chemical supplier for chemical compatible materials.

MANUFACTURER'S PRODUCT WARRANTY

The manufacturer warrants its equipment of its manufacture to be free of defects in material or workmanship. Liability under this policy extends for twenty-four (24) months from the date of purchase or one (1) year from date of installation or whichever comes first. The manufacturer's liability is limited to repair or replacement of any device or part which is returned, prepaid, to the factory and which is proven defective upon examination. This warranty does not include installation or repair cost and in no event shall the manufacturer's liability exceed its selling price of such part.

The manufacturer disclaims all liability for damage to its products through improper installation, maintenance, use or attempts to operate such products beyond their functional capacity, intentionally or otherwise, or any unauthorized repair. Replaceable elastomeric parts are expendable and are not covered by any warranty either expressed or implied. The manufacturer is not responsible for consequential or other damages, injuries or expense incurred through use of its products.

The above warranty is in lieu of any other warranty, either expressed or implied. The manufacturer makes no warranty of fitness or merchantability. No agent of ours is authorized to make any warranty other than the above.

For warranty and service matters within the European Union, contact the seller first or:

Pulsafeeder, Inc. Europe Units 12 and 13, Edison Road Highfield Industrial Estates Eastbourne, East Sussex BN23 6PT

PRECAUTIONS FOR OPERATION

Each Series 100/150 chemical feeder has been tested to meet prescribed specifications and certain safety standards. However, a few precautionary notes should be adhered to at all times. THOROUGHLY READ ALL CAUTIONS PRIOR TO INSTALLING METERING PUMP.



- Chemicals used may be dangerous and should be used carefully and according to warnings on the label. Follow
 the directions given with each type of chemical. Do not assume chemicals are the same because they look alike.
 Always store chemicals in a safe location away from children and others. We cannot be responsible for the
 misuse of chemicals being fed by the pump.
- 2. Always wear protective clothing (protective gloves and safety glasses) when working on or near chemical metering pumps.
- 3. Tampering with electrical devices can be potentially hazardous. Always place chemicals and feeder installation well out of the reach of children and others.
- 4. Be careful to check that the voltage of the installation matches the voltage indicated on the specification label. Each pump is equipped with a three prong plug. Whether plugging into a receptacle or wiring into a system, always be sure the feeder is grounded. If receptacle is utilized, to disconnect, do not pull wire but grip the plug with fingers and pull out.
- 5. Never repair or move the metering pump while operating. Always disconnect electrical current. Before handling the pump always allow sufficient time for the motor housing to cool off. Handling the pump too soon after shutdown may cause hand burns. For safety use protective gloves.
- 6. All pumps are pretested with water before shipment. Remove head and dry thoroughly if you are pumping a material that will react with water, (e.g. sulfuric acid). Valve seats, ball checks, gaskets, and diaphragm should also be dried. Before placing feeder into service, extreme care should be taken to follow this procedure.
- 7. Arrows on the pump head and injection fitting indicate chemical flow. When properly installed, these arrows should be pointing upward.
- 8. When metering hazardous material DO NOT use plastic tubing. Strictly use proper rigid pipe. Consult supplier for special adaptors.
- 9. Pump is NOT to be used to handle or meter flammable liquids or materials.

- 10. Standard white polyethylene discharge tubing is not recommended for installations exposed to direct sunlight. Consult supplier for special black polyethylene tubing.
- 11. Manufacturer will not be held responsible for improper installation of pumps, or local plumbing conducted. All cautions are to be read thoroughly prior to hook-up and plumbing. For all installations a professional plumber should be consulted. Always adhere to local plumbing codes and requirements.
- 12. Note the maximum pressure rating of the metering pump. When used with pressurized systems, always be sure the pressure of the system does not exceed maximum pressure rating listed on the specification label.
- 13. Be sure to depressurize system prior to hook-up or disconnection of metering pump.

INSTALLATION, PIPING AND WIRING

UNPACKING, ASSEMBLING AND MOUNTING:

The carton should contain:

- Metering Pump
- ✤ 4 ft. (1.21 m) Clear Flexible Suction Tubing
- ✤ 4 ft (1.21 m) Stiff White Return Tubing
- Feeder can be mounted on a wall shelf bracket (Figure B), tank stand platform (Figure C), directly on the wall (Figure D), or directly on the tank cover (Figure E).
- Bleed Valve Assembly
- Instructions
- Strainer Assembly w/Tube Weight
- Back Check Valve Assembly
- 8 ft (2.43 m) Stiff White Discharge Tubing (Optional black tubing for UV protection available from the factory)



To mount the feeder directly on the wall, place the feeder base against the wall with the motor below the pumping head, remove four head mounting bolts, and turn head quarter turn so suction is in bottom position.

IMPORTANT: Injection point must be higher than top of solution tank to prohibit gravity feeding. Maximum head in meters is 70m/H O for Series 100 Model pumps and 42m/H O for Series 150 Model pumps.



NOTE: Make sure the arrow on the outside of the pump head is pointing upward. The pump must be positioned so that the plug is accessible.

Flooded suction mounting Fig. C (installing feeder at the base of tank on a platform) is the most trouble free type of

installation. (Tank stands and platforms are available for all size feeders and tanks). The pump is secured on the platform, and then the clear suction tubing is attached to a bulkhead fitting assembly and the suction valve housing on the pump head. Since the suction tubing is always filled with solution, priming is accomplished much more guickly and the chance of losing prime on an installation where the feeder is used only a few hours a day, is greatly reduced. The feeder comes with a bleed valve assembly that attaches to the discharge valve in the pump head. The bleed valve allows you to manually prime the feeder and depressurize the discharge line without disconnecting the feeder from the tubing connections.



NOTE: To operate without bleed valve, replace bleed

valve (item #49) and 0.38 in. (0.96 cm) -tubing size discharge valve housing (item # 42) with a 0.50 in. (1.27 cm) -tubing size discharge valve housing (item #42) and coupling nut (item #43). See page 12 (Wet End Assembly). Items #42 and #43 are available from factory.

Assemble tubing and fittings to the feeder (Fig. G).

MOUNTING HOLE PATTERN

A CAUTION Do not force fittings, HAND TIGHTEN ONLY. Do not use additional sealants, such as pipe tape, on tubing fittings. Use additional sealants, such as pipe tape, on pipe fittings and tighten normally.

CAUTION If water is used to dissolve solid chemicals or create a dilute solution, the chemical tanks should be manually filled or an approved means must be used to prevent a cross connection between the chemical tank contents and the potable water line. Check local plumbing regulations.

CHEMICAL INJECTION:

Chemical injection into an open tank: The discharge tubing can be placed in an open tank with or without the injection valve assembly. Each feeder is shipped with a spring loaded back check injection valve. This assists in a positive seal on the discharge side of the pump head preventing back flow.

Pumps carrying the 'NSF' or the 'ETL Sanitation' (tested to NSF standard-50) approval are listed for swimming pools, spas, and hot tubs, and when proper materials are selected, are capable of handling but not limited to the following chemical solutions.

12 /2% sodium hypochlorite 2% calcium hypochlorite 12% aluminum sulfate 10% hydrochloric acid 10% sodium hydroxide 5% sodium carbonate.

INSTALLATION INTO A WELL PUMP SYSTEM:

Make sure the voltage of the feeder matches the voltage of the well pump. Install the injection fitting into a tee which is installed into the water line going to the pressure tank. The end of the injection check valve should be in the main stream of the water line. A typical installation is shown in Figure H. For installation of pump for operating swimming pools, pump is to be supplied by an isolating transformer or thru an "RCD" (residual current device).



NOTE: It is recommended to install the injection assembly in a vertical position on the bottom side of the water line (Figure J).

This will insure proper sealing of the injection assembly check valve and prevent a back flow into the feeder's discharge line. Be sure arrow on injection fitting is pointing upward.

DOWN-THE-WELL INSTALLATION:

Often it is desirable to provide chemical feed near the intake of the well pump for additional retention time and mixing of the chemicals. An additional length of discharge tubing will be required for this installation. Secure the end of the discharge tubing to the pump cylinder, drop pipe, or foot valve and lower it into the well. An anti-siphon valve must be installed on systems such as this where the discharge is lower than the feeder and the chemical storage tank. **Failure to install anti-siphon valve may allow siphoning to occur.**

ANTI-SIPHON VALVE: (optional)

Under any installation condition where the possibility of siphoning or suction may occur on the discharge side of the pump, install an anti-siphon valve on the discharge side of the

feeder. The anti-siphon valve is not part of **FIG.** H the standard package. This item can be furnished by your dealer at extra cost.

PRESSURE RELIEF VALVE: (optional)

Series 100/150 chemical pumps are rated to pump against a line pressure up to 100 PSI (7 BAR). If the line pressure on an installation could fluctuate above 100 PSI (7 BAR), install a pressure relief valve on the discharge side of the pump head. Once the pressure reaches a certain level, the pre-set relief valve will return the solution being pumped back to the solution tank. This will prevent motor burnout or diaphragm rupture. The relief valve is not part of the standard package. This item can be furnished by your dealer at extra cost. Read relief valve instructions carefully before installing.

BLEED VALVE INSTALLATION: (optional)

NOTE: After disconnecting power to the pump and taking necessary safety precautions regarding the chemical and system.

- 1. Remove the coupling nut and tubing from the discharge port of the pump.
- 2. Remove the valve housing from the discharge side of the pump head and replace it with the .38inch valve housing from the kit (this step is not required if the pump is already fitted for .38inch tubing.
- 3. Install the TFE gasket over the discharge fitting.
- 4. Install the bleed valve assembly over the discharge fitting and gasket.
- 5. Install the bypass tubing from the kit into the bypass port of the bleed valve and hand-tighten the coupling nut. Bypass tubing should be connected to return bypassed liquid back to the solution tank.
- 6. Install the discharge tubing into the discharge port of the bleed valve and hand tightens the coupling nut.



TO Δ ANTI-SIPHION VALVE 8 WIRE METERING PUMP TO RUN WHEI WELL PUMP RUNS TANK, WALL SOLUTION θ MIN 42 GAL PHESSU SWITCH 8 CHECK TEE BALL OR GATE VALVE TO FILTER 8 WATER (000) POWER TO PUMP V

TYPICAL DOMESTIC WATER TREATMENT INSTALLATION



 Return the system to operating conditions and reconnect the power to the pump. The pump is now ready for priming and operation. Always use caution and check for leaks at newly assembled connections.

CURRENT INTERRUPTER: (optional)

CURRENT INTERRUPTER ON/OFF CYCLE TIME

DIAL SET AT	RUN TIME	OFF TIME
LOW SETTING	3-SECONDS ON	50-SECONDS OFF
#2 SETTING	5-SECONDS ON	20-SECONDS OFF
#3 SETTING	5-SECONDS ON	12-SECONDS OFF
#4 SETTING	7-SECONDS ON	9-SECONDS OFF
#5 SETTING	8-SECONDS ON	7-SECONDS OFF
#6 SETTING	11-SECONDS ON	6-SECONDS OFF
HI SETTING	CONTINUOUSLY ON	NO-OFF

Air Bleed Operation:

- 1. While pump is running, turn the bleed valve knob counter clockwise.
- 2. Run with valve open until a solid stream of fluid comes out of the bypass tubing (.38inch tubing supplied with valve)
- 3. Close air bleed valve by turning the bleed valve knob clockwise.

HAND TIGHTEN FITTINGS:

When connecting tubing to suction and discharge fittings, the coupling nuts should be tightened hand tight only. Excessive tightening can cause cracks in pump head.

POINT OF INJECTION:

Pipe corrosion can result if dillution at the injection point does not occur rapidly. This problem is easily prevented by observing this simple rule: install injection fitting so that the end is in the flow stream of the line being treated. **NOTE:** Extended injection assemblies are available for large water lines. Consult your dealer.

COMMON ERRORS IN THE INJECTION OF CHEMICALS:

Do not insert the injection fitting into a pipe stub in the tee. A full strength solution will often cause corrosion or scale in the pipe stub when it is not in the flowing stream (Figure J). The maximum lift of the chemical feeder is five feet. Be sure not to exceed this height. It is very important that the arrow on the fittings and the pump head point vertically upward in order to prevent backflow. Arrows indicate the proper flow of the chemical.

POWER

The standard chemical feeder is available in115 volt 60 cycle single phase. 230 volt 60 cycle and 230 volt 50 cycle single phase can also be made available upon request.

CAUTION Be sure the voltage of the feeder matches the power supply. (Figure M)





When working on or around metering pump installation, protective gloves and safety glasses should be worn at all times.

PRIMING

CAUTION All pumps are tested with water (e.g. sulfuric acid, polymer) the pump head should be removed and dried thoroughly along with the diaphragm and valve seats.

If the discharge line is connected directly to a pressurized system it should be temporarily bypassed during priming of the pump. This pump is equipped with a bleed valve to simplify this operation by allowing easy bypass of the discharge fluid. All air must be purged from the pump head before the pump will pump against pressure. Turn on the power to the pump. Loosen the locking lever by turning it counter-clockwise and turn the output adjusting knob counter-clockwise to full capacity, (one full turn only) then tighten the locking lever by turning clockwise to a hand tight position. Solution should be primed to the head within a few minutes. (Refer to Figure K)

Air Bleed Operation: A) While pump is running, turn adjustment screw counterclockwise. B) Run with valve open until a solid stream of fluid comes out of the bypass tubing (0.25 in (0.63 cm) ID x 0.38 in (0.96 cm) OD) supplied with valve, no air bubbles. C) Close air bleed valve by turning adjustment screw clockwise.

NOTE: The feeder is adjustable only while running; never force the output adjustment knob. Do not turn the adjustment knob while the pump is stopped. If the solution hasn't reached the head in a few minutes, disconnect power to the pump, make sure the system is depressurized, remove the discharge tubing and discharge fitting and dampen the discharge valve area (ball check and valve seats) with a few drops of solution being fed by the pump. For safety, use protective gloves and safety glasses and a proper container to hold chemical. Replace the fitting and tubing and restart the pump.

Turn the power on once more and adjust the pump to the proper rate, using the locking lever as before.

<u>A</u> CAUTION When working on or around metering pump installation, protective gloves and safety glasses should be worn at all times.

CAUTION Check calibration of the pump before leaving the installation site. A test for chemical residual in the treated water is the best indication of the correct pump setting.

MAINTENANCE:

SCALE: GASKETS AND CHECK VALVES

When checking the metering pump or providing routine maintenance, replace all valve seats or ball checks if any of them show any wear or deterioration. (Valve seats should be checked approximately every 4-6 months depending upon the application.) Repeated deterioration of valve seats and other rubber or plastic parts within a few months period usually indicates another material should be used for the defective part. Contact your supplier or see the parts list for parts affected for possible alternate materials.

OUTSIDE INSTALLATION:

In many areas where freezing conditions are not a problem it is common to install a metering pump outside. Adequate protection should be provided to keep the pump from being exposed to direct sunlight or rain. Any simple covering adequately ventilated will afford the necessary protection from weather. **NOTE:** When discharge tubing is exposed to direct sunlight, black polyethylene tubing should be used in lieu of the stiff white translucent tubing supplied with each pump.

• SOLUTION TANK:

Check the solution tank for settling of chemicals. If there is sludge on the bottom of the solution tank, clean the strainer, the foot valve, and the solution tank. Installing the foot valve a few inches above the bottom of the tank will prevent future clogging. **NOTE: If the chemical being pumped regularly precipitates out of solution or does not dissolve easily or completely (calcium hydroxide), mixers are readily available in different motor configurations and mountings.**

OUTPUT ADJUSTING KNOB:

Sometimes the output adjusting knob can move on its shaft and cause a false output indication. This can happen if the knob set-screw slips or if the unit is disassembled for any reason. The unit can be reset to "0" as follows:

- 1. Remove the dial stop.
- 2. With the pump running, loosen the locking lever and turn the adjusting knob counter-clockwise until it is "loose" to touch.
- SLOWLY re-screw the knob clockwise, using very light finger pressure. It will soon start to advance in pulses as the internal cam comes in and out of contact.



- 4. When light finger pressure will no longer allow movement of the knob between cam contacts, grasp the knob securely and tighten the locking lever (turning clockwise) making sure that the knob does not move. To check for zero point, turn on pump. There should be no liquid coming out of discharge fitting.
- 5. Replace dial stop.
- 6. If the pointer is not at "0", loosen the set-screw on the knob (use a .078 in Hex key), and turn pointer to "0", then retighten the set-screw while holding the knob in place.
- 7. A setting of "0" will now give zero output. One full revolution of the knob counter clockwise will give maximum output. The knob should never be turned more than one full revolution.

SERVICING AND REPAIRS

A CAUTION REPLACEMENT OF PUMP HEAD ASSEMBLY OR DIAPHRAGM:

Before performing any repairs on Series 100/150 chemical feeders, be sure to disconnect all electrical connections and relieve pressure from suction/discharge tubing.

The Series 100/150 feeder was designed so that servicing can be quick and simple. Proper part replacement procedures are described below.

NOTE: Use protective gloves and safety glasses when working on or around chemical feeder.

- Disconnect the tubing. Remove the suction valve and discharge valve being careful not to lose the ball checks and any other small parts. (Figure N)
- 2. Remove the four screws from the face of the head and remove the head.
- Remove the diaphragm by inserting one or two of the head bolts into the holes of the diaphragm and turning counter-clockwise. (Figure O)
- 4. A new pump head or diaphragm should be installed if either is broken or cracked (see parts list at the end of this manual). The new pump head can be installed by going through the above steps in reverse.
- 5. Be sure the drive bracket assembly is in the **fully retracted position** when installing the new diaphragm. Install the new diaphragm by screwing it in hand tight, then, back off one-fourth turn or until screw holes are lined up.
- Replace the head and the head screws, being certain the discharge fitting is up. NOTE: Arrow on outside of pump head should be in vertical position pointing upward. Tighten the head screws evenly and carefully to prevent cracking the head.
- 7. Replace the suction and discharge fittings making sure all gaskets and valves are fitted properly. Do not use pipe tape or other sealants. **HAND TIGHTEN ONLY.** Restart the system as in the start up procedures (INSTALLATION).

BALL CHECKS AND VALVE SEAT REPLACEMENT:

The following procedure is the same for any of the four valves.

Make sure all electrical connections are disconnected and pressure valves off.

NOTE: Use protective gloves and safety glasses while replacing parts.

- 1. Unscrew compression nut and remove tubing.
- 2. Unscrew check valve body from pump head, foot valve, or injection fitting.
- 3. Remove all seats, ball checks, and gaskets and replace.
- 4. Replace the check valve body so fitting makes contact with the gasket and the pump head, foot valve or injection fitting, whichever the case

may be. HAND-TIGHTEN FITTINGS ONLY. Do not use pipe tape or other sealants on these threads.

- 5. Re-install the tubing and tighten coupling nut **HAND TIGHT.**
- 6. Restart the system as in the INSTALLATION PROCEDURES.





TROUBLESHOOTING

PROBLEM	PROBABLE CAUSE	REMEDY			
	1. Pump setting too low.	1. Adjust to higher setting (feeder must be operating during the stroke length			
LOSS OF	2 Coole at injection point	adjustment).			
CHEMICAL	2. Scale at Injection point	3. Refill the tank with solution and prime. See Start-Up Section			
RESIDUAL	3. Solution container allowed to				
	run dry				
	2. Chemical in solution tank too	2. Dilute chemical solution, NOTE: For chemical that reacts with water, it may			
TOO MUCH	rich.	be necessary to purchase a more dilute grade of chemical direct from			
CHEMICAL	3 Sinhoning of chemical into	chemical supplier.			
	well or main line	anti-siphon valve. See Figure G.			
LEAKAGE	1. Worn tube ends	1. Cut off end of tubing (about 1") and then slip on as before or replace			
	2. Chemical attack	suction valve housing and compression fitting to prevent leakage. 2. Consult your chemical supplier for compatible materials.			
	1. Leak in suction side of pump.	1. Examine suction tubing. If worn at the end, cut approximately an inch off			
		and replace or replace valve body and coupling nut.			
	2. Valve seats not sealing.	2. Clean valve seats if dirty of replace with proper material if deterioration is noted.			
	3. Low setting on pump.	3. When pumping against pressure, the dial should be set above 40%			
FAILURE TO PUMP OR FEED	4. Low solution level.	maximum rated capacity for a reliable feed rate.			
	5. Diaphragm ruptured.	5. Replace diaphragm as shown in "Service" Section. Check for pressure			
		above 100 PSI (7 BAR) at the injection point. NOTE: Chemical incompatibility with diaphragm material can cause diaphragm runture and leakage around			
		the pump head.			
	6. Pump head cracked or broken	6. Replace pump head as shown in "Service" Section, Do not use pipe tape			
	broken.	can crack pump head. Also, chemical incompatibility can cause cracking and			
	7 Dump hand contains air ar	subsequent leakage.			
	chlorine gas.	clockwise until air is purged. Close bleed valve.			
	1. Dirty check valve.	1. Remove and replace or clean off any scale or sediment.			
	2. Ball checks not seating or not sealing properly	Check seat and ball checks for chips, clean gently. If deformity or deterioration is noted, replace part with proper material. Chemical			
PUMP LOSES PRIMF		crystallization can hold check valves open, therefore the valves must be			
	3 Solution container allowed to	disassembled and cleaned. Be sure to replace all parts as shown in the Parts			
	run dry	3. Refill the tank with solution and prime.			
	1. Loose fittings	1. All fittings can be hand tightened to prevent leakage. Clean off chemicals			
FITTING	2. Broken or twisted gasket	which have spilled on pump. 2. Check gaskets and replace if broken or damaged.			
	3. Chemical attack	3. Consult your chemical supplier for compatible materials.			
	1. Too much pressure at	1. Open bleed valve and circulate fluid until all air is purged from pump head			
PUMP WILL NOT	2. Check valves not sealing	2. Disassemble, loosen, clean and check for deterioration or swelling.			
PRIME	2. Output dial act act at	Reassemble and wet the valve assembly, then prime. See INSTALLATION			
	maximum	3. Always prime pump with output dial set at maximum rated capacity.			
ANTI-SIPHON	1. Scale or particles have	1. Remove, clean and reassemble, being careful not to wrinkle the			
VALVE	plugged diaphragm	diaphragm. Check sequence and position of parts to be sure reassembly is			
MALFUNCTION	2. Ruptured valves	2. Consult your distributor for replacement.			
	1. Pumping against excessive	1. Test pressure to determine if it exceeds pump specifications. If so, consult			
STALLS	pressure 2. Low voltage to pump	your distributor. 2. Make sure voltage of power source matches the voltage on the pump			
_		specifications label. If not transformers are available.			
MOTOR RUNNING VERY HOT	1. Low voltage.	1. Power supply voltage should match voltage on pump specification label.			
	transformer, it may be				
	undersized for the pump				

SERIES 100/150 DRIVE ASSEMBLY



* = ITEMS INCLUDED IN HOUSING ITEM #1.

S	ER	IES	100/150	WE	ETEND	ASS	SEMBLY
			•				\bigcap
						_	
						(5	9
ITEM	PART #	I	DESCRIPTION	OTY		(5	3)
11	25704	DIAPHRAGM (I	HYP) AS'Y	1			
	25706	DIAPHRAGM (V	VIT) AS'Y				(h
	25707	DIAPHRAGM (IFE) AS'Y			\frown	
19	28800	HEAD (SAN-A	CRYLIC), PUMP	1		\sim	
	J28801	HEAD (PVC),	PUMP	4			
	28803	HEAD (FPP),	PUMP	<u> </u>	ý v	(52) ~	
23	J37005	SCREW (SST)	, #10-24 x 21n1g. PHP	4		\bigcirc	
30	J42020	WASHER (STL)), #IU-FLAT	4			
41	11540	BODI (PVC),	SUCTION VALVE Ø.51nTUBE			12007	
	41551	BODY (PVC)	SUCTION VALVE Ø 38in -TUBE	-	AT >	49	
	41552	BODY (FPP)	SUCTION VALVE Ø 38in -TUBE	-			
42	J41540	BODY (PVC)	DISCHARGE VALVE Ø.5inTUBE	1		メ	
25.541	41541	BODY (FPP) .	DISCHARGE VALVE Ø.5inTUBE		-	(16)	SEE DRIVE
	41543	BODY (PVC) ,	DISCHARGE VALVE Ø.38inTUBE	1	- A	40	(1) ASSEMBLY
	41544	BODY (FPP),	DISCHARGE VALVE Ø.38inTUBE	1			~
43*	J24960	NUT (PVC), (COUPLING Ø.50inTUBE STD.	2	* 43		
	24961	NUT(FPP), (COUPLING Ø.50inTUBE			SEE	\sim
	24963	NUT (PVC), (COUPLING Ø.38inTUBE	4		NOTE C	
	24964	NUT (FPP), (COUPLING Ø.38inTUBE				1) 0
44	J20560	BALL (CER),	Inq_command				
45	J37440	SEAT (HYP),	VALVE	- ²			
16	J3/442	SEAT (VIT),	VALVE	2_2		44	
40	.760717	STRAINER A	/ S'Y/FOOT VALVE (DVDE/HVD/C/0/38	2-3	(45) O	ad IE	
/	J60718	STRAINER AS	S'Y/FOOT VALVE (PVDF/VTN/C/Ø.38			40	long
	J60729	STRAINER AS	S'Y/FOOT VALVE (PVDF/HYP/C/Ø.50	8			
	J60730	STRAINER AS	S'Y/FOOT VALVE (PVDF/VTN/C/Ø.50			100 - +01	
48	L9906700-	-000 WEIGHT	(CER), STRAINER	1		K \	
49	J30507	KIT, BLEED	VALVE PVC/HYP/Ø.38inTUBE	1			\bigcirc
	J30509	KIT, BLEED	VALVE PVC/VTN/ "				0
	J30510	KIT, BLEED	VALVE PVC/TFE/ "	-		T X	-Х
	U3U511 T20512	KIT, BLEED	VALVE FPP/HYP/ "	-			シ
	J30513	KIT BLEED	VALVE FPD/TFE/	-		(19)	
	J30515	KIT, BLEED	VALVE PVC/HYP/Ø 50in -TUBE	-		9	
	J30517	KIT, BLEED	VALVE PVC/VTN/ "	1	46		
	J30518	KIT, BLEED	VALVE PVC/TFE/ "	1		-(45)	
	J30519	KIT, BLEED	VALVE FPP/HYP/ "]			
	J30521	KIT, BLEED	VALVE FPP/VTN/ "	1		-(41)	
	J30522	KIT, BLEED	VALVE FPP/TFE/ "				
50	41693	INJECTION 1	FITTING PVC/HYP/C Ø.38inT	1	L A		
E.4	J41694	INJECTION]	FITTING PVC/HYP/C Ø.50inT	1 51		43	
51	00006	SUCTION TU	$\frac{1}{2} \frac{1}{2} \frac{1}$	4-IC.		/	
52	00007	DISCHARGE '	$\frac{1}{2} \frac{1}{2} \frac{1}$	8-F+	l vu		\sim
52	00009	DISCHARGE	TUBING (PE-BLK) Ø.50in0.D.	1		11	
	00010	DISCHARGE !	TUBING (PE-WHT) Ø.38inO.D.	1		//	Ý
	00011	DISCHARGE	TUBING (PE-BLK) Ø.38inO.D.	1			\bigcirc
53	J39010	SPRING, IN.	JECTION BACKCHECK (not shown)	1	/		
54	J38985	SPRING (HCO)), HEAVY S100/2/3/INJ (SEE NOTE)	1	(51)		

(48)

(47)

* NOT USED WITH BLEED VALVE. (NOTE: X003 AND X007 ONLY)